

From: [Annabel Elleray](#)
To: [Anna Romanenko](#)
Subject: 77661 111a Purley Lane
Date: 20 October 2022 17:21:12
Attachments: [image001.png](#)
[image003.png](#)

Hi Anna,

Good to speak to you earlier – apologies regarding the technical issues on my side.

Regarding the percentage reduction in surface water discharge, this would be 42% - this is a decrease in discharge rate from 1.42 l/s (the existing runoff rate for the 1 in 100 year event) to 1 l/s (the proposed discharge rate). It is worth noting in case the Council mentions this further that the 1 l/s discharge rate has been proposed as this is normally considered the lowest feasible rate – any lower, and the potential for blockages (and hence flooding) to occur is greatly increased!

Thanks,
Annabel

 **GeoSmart** Information
Annabel Elleray
Project Consultant

  **COPSO**
ASSOCIATE MEMBER

[Register for FREE CPD](#)

t. +44 (0)1743 298 100
d. +44 (0)1743 295 278
e. annabelelleray@geosmartinfo.co.uk
[@geosmartinfo](#)
www.geosmartinfo.co.uk

GeoSmart is registered with the Property Codes Compliance Board as a subscriber to the Search Code.

Confidentiality Notice

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. They may also be legally privileged. If you have received this email in error please notify us immediately by reply and destroy any copies. GeoSmart Information Ltd. is registered in England & Wales under registration number 5475394. Registered Address: Suite 9-11, 1st floor, Old Bank Buildings, Bellstone, Shrewsbury, SY1 1HU.



Please consider the environment before printing this email.